

From: Weiss-Ishai, Sagiv (FIR) <sagiv.weiss-ishai@sfgov.org>
Sent: Wednesday, October 16, 2024 3:50 PM
To: Sujeski, Crystal@CALFIRE <Crystal.Sujeski@fire.ca.gov>; Andersen, Greg@CALFIRE <Greg.Andersen@fire.ca.gov>
Cc: Weiss-Ishai, Sagiv (FIR) <sagiv.weiss-ishai@sfgov.org>
Subject: CFC supplement Section

Per the State agency meeting yesterday it was agreed by everyone that UL 217 Smoke Alarm shall not be permitted in R-2 College and University

However, there is still a confusion in the supplement language indicating “Required smoke alarms and detectors listed in accordance with UL 268...”

Since per the FAAC recommendations and all CAFAA members (and Crystal and Greg as well) everyone agrees that UL 217 Smoke Alarms shall not be permitted and ONLY Smoke detectors listed to UL 268 shall be permitted – I think that this should be a simple editorial/typo correction and the NEW language should say:

“Smoke Detectors listed in accordance with UL 268, in dwelling units and sleeping units in Group R-2 occupancies operated by college or university for student or staff housing shall be interconnected with the fire alarm system to activate the occupant notification in accordance with NFPA 72 and shall comply with Section 907.2.11.7”

907.2.9.3 Group R-2 college and university buildings.

An automatic smoke detection system that activates the occupant notification system in accordance with Section 907.5 shall be installed in Group R-2 occupancies operated by a college or university for student or staff housing in all of the following locations:

1. Common spaces outside of dwelling units and sleeping units.
2. Laundry rooms, mechanical equipment rooms and storage rooms.
3. All interior corridors serving sleeping units or dwelling units.

> *Required smoke alarms and detectors listed in accordance with UL 268, in dwelling units and sleeping units in Group R-2 occupancies operated by a college or university for student or staff housing shall be interconnected with the fire alarm system to activate the occupant notification in accordance with NFPA 72 and shall comply with Section 907.2.11.7.*

Can you please get this simple change done – Let me know what is the best way to get this done in the next cycle

Sagiv