

From: [Austin Barolin](#)
To: [CBSC@DGS](#)
Cc: [Enright, Lawrence@HCAI](#); [Travis R. English](#); [Marvelli, Mia@HCAI](#); [Nelson, Ryan@HCAI](#); [Mason, Dave](#)
Subject: Title 24, Part 4 - Edit to Section 407.5.1.4 - New Requirement 2025 OSHPD Amendments to 2025 California Mechanical Code
Date: Monday, August 12, 2024 5:57:26 PM
Attachments: [image001.png](#)
[image003.png](#)

CAUTION: This email originated from a NON-State email address. Do not click links or open attachments unless you are certain of the sender's authenticity.

407.5.1.4



Comment #1:

407.5.1.4 introduces repetitive language of 407.5.1 while also being more restrictive compared to the previous code language by stating that "sensitive areas must be constant volume". This is also a restriction beyond ASHRAE Standard 170 with no clear justification or intent behind it. It is recommended that 407.5.1.4 should not be issued into the 2025 Code Cycle.

Austin Barolin, PE, CEM, LEED AP (he/him/his)
Senior Associate | Senior Energy & Decarbonization Analyst

MAZZETTI

D: 415.364.7229 C: 609.206.1991



[2023 Benefit Corporation Report: Real impact. Realized](#)