

From: [Joe Panushka](#)
To: [HCAI OSHPD RegsUnit](#)
Subject: RE: 2025 CMC Amendments - Table 4A for Clinics
Date: Tuesday, July 30, 2024 5:36:08 PM

CAUTION: This email originated from outside of the organization.

Mia and Lori,

Looking at the most recently proposed revisions for the 2025 CMC, footnote (q) is missing from the “All room air exhausted directly to outdoors” column for Primary Care Waiting Rooms. I believe that this footnote should still apply to these Waiting rooms, since the footnote appears to have carried over to all the other Waiting Rooms where it was allowed in the 2022 CMC.

Joe Panushka AIA

Principal

Rasmussen & Associates
21 S. California Street, Fourth Floor,
Ventura, CA 93001

Please note new phone numbers:

Direct (805) 871-4212

Office (805) 648-1234 ext. 124

FAX (805) 648-4444

JPanushka@RA-Arch.com

This message has been scanned for malware by Forcepoint. www.forcepoint.com